

**Check List (53 Points) of fire Installation proposal/Plan
(Fire NOC)**

1	Name of the building	KNOWLEDGE PUBLIC SCHOOL
2	Address of the Building	KH NO 27/1 & 28/1, GRAM-SODALPUR, BLOCK TIMARNI, THE RAHATGAON, DIST- HARDA
3	Name and Address of builder/promoter	M/S KUSUM DEVI SHIKSHAN & SAMAJ KALYAN SAMITI GRAM-SODALPUR, BLOCK TIMARNI, THE RAHATGAON, DIST- HARDA
4	Name and Address of owner/occupiers of Individual Flats.	SH. AKHILESH AGRAWAL GANDHI CHOUK, TIMARNI, HARDA
5	Plot Area a. Title b. Land use (in case of residential building Indicate no. of dwelling units)	2 ACRE School Building
6	Covered area (at grade level)	947 SQM
7	Height of the building	8 mtr
8	a. Overall height (from grade level) b. Approved/Provisional set back areas conforming to building bye-laws are as follows : 1. Front- 2. Back – 3. Left Side – 4. Right Side –	8 mtr 12 mtr 06 mtr 06 mtr 06 mtr
9	a. Number of basements (Please Indicate level below grade in each case) b. If basement extends beyond the building line, please indicate the load bearing strength of the roof of basement. c. Area of basement d. Whether any piazza is proposed? If so, details of the level of piazza and ramps etc. be indicated	Nil


PRESIDENT
KNOWLEDGE PUBLIC SCHOOL
TIMARNI


Secretary
**Kusumdevi Shikshan & Samaj
Kalyan Samiti, Timarni**


PRINCIPAL
KNOWLEDGE PUBLIC SCHOOL
TIMARNI

10	Number of Floors (including ground floor)	Permitted- G+3 Constructed-G+1 =2 (2 NOS)
11	Occupancy (Use-please mention separately for basement & floors)	SCHOOL BUILDING, CLASS ROOMS AND OFFICE
12	Covered area of typical floor of bldg. Blocks.	1894 SQM
13	Parking areas (please give details)	OPEN
14	Details of surrounding property features	Property is Surrounding by other open area
15	Approach to proposed building, width of the road and connecting roads, if any	60 FT wide road
16	Please give details of water supply available exclusively for fire fighting.	10000Ltr/ OH water Tank
17	Has wet riser(s) been provided? If so, please indicate the number of risers and internal dia of each.	N.A.
18	Has any down comer been provided? If so, please give details.	NO
19	Please indicate the present arrangement for replenishment of water for fire fighting.	Bore well / overhead tank
20	Is a public or other water storage facility available nearby? If so, please give the capacity and distance from your building, also please indicate if it is readily accessible.	Na
21	Please give any other information that you can, regarding availability of water supply for fire fighting.	NA
22	Have internal hydrants been provided If so, please indicate no. of hydrants on each floor including basement(s) and terrace.	Na
23	Have first add-hose reels been provided? If so, please indicate: a. No. of hose reels on each floor including basement(s) b. Bore and length of hose-reel tubing on each reel.	YES 1 in each floor 20 mm X 30 MTR 5mm shut Off Nozzle


PRESIDENT
KNOWLEDGE PUBLIC SCHOOL
TIMARNI


Secretary
Kusumdevi Shikshan & Samaj
Kalyan Samiti, Timarni


PRINCIPAL
KNOWLEDGE PUBLIC SCHOOL
TIMARNI

	c. Size (bore) and type of nozzle fitted to each hose reel. d. Is the hose reel connected directly to the riser or to the hydrant outlet?	
24	Has fire hose been provided near each hydrant? If so, please indicate a. The type of hoses b. The size (bore) of hoses. c. The length of each hose d. Total number of hoses provided near each hydrant.	Na
25	Have branch pipes been provided? If so, please Indicate a. The type of branch pipes b. Size of nozzle fitted to each branch	Na
26	a. If the basement is used for car parking or storage, has it been sprinkled? b. Whether any cubicals proposed in the basement? If so, the area of each cubical be indicated? c. Whether segregation/compartmentation of the basement has been provided? If so,please indicate	Na
27	Is the building equipped with automatic fire detection and alarm system? If so, please indicate: a. The type of detectors used b. The standard to which the detectors confirm c. The code to which the installation confirms.	Na
28	Have manual call boxes been installed in the building for raising an alarm in the event of an outbreak of fire? If so, please give details	NA
29	Has public address system been provided between the various floors and the fire control room in entrance lobby?	No
30	Has an intercom system been provided between the various floors and the fire control room in entrance of the building?	No
31	Has a fire control room be provided in the entrance lobby of the building?	No
32	How many staircases have been provided in the building? Please indicate in each case: a. Width of the stairway	01 Nos. 1100 mm 250 mm


PRESIDENT
KNOWLEDGE PUBLIC SCHOOL
TIMARNI


Secretary
Kusumdevi Shikshan & Samaj
Kalyan Samiti,Timarni


PRINCIPAL
KNOWLEDGE PUBLIC SCHOOL
TIMARNI


	b. Width of the treads c. Height of the rigors d. if the treads are of the non-slip type.	150 mm Yes
33	What is the average occupant load per floor?	—
34	How many lifts have been installed in the building? Please indicate in each case. a. The floors between which the lift runs. b. The type of doors fitted to the lift car and at each landing c. Fire resistance rating of lift car and landing doors, if known. d. Floor area of the lift car. e. Loading capacity of the lift car. f. Has communication system been installed in the lift for car? g. Has a Fireman's switch been installed in the lift for grounding it in the event of fire?	nil
35	Have any stationary fire pump(s) been installed for pressurizing the wet riser? If so, please indicate a. The number of pumps b. The size of suction and delivery connection of each pump c. The output of each pump. d. The maximum head against which the pump can operate at the output mentioned at (c) e. Is the pump automatic in action?	Yes For hose reel 01 Nos booster 80X80 450 Lpm — No
36	Has a standby source of power supply been provided? Lift is through a generator, please indicate a. the capacity (output) b. the functions that can be maintained simultaneously by the use of generator, such as operating lift(s) fire pumps emergency lighting etc. c. Is the generator automatic in action or has to be started manually?	nil


 PRESIDENT
 KNOWLEDGE PUBLIC SCHOOL
 TIMARNI


 Secretary
 Kusumdevi Shikshan & Samaj
 Kalyan Samiti, Timarni


 PRINCIPAL
 KNOWLEDGE PUBLIC SCHOOL
 TIMARNI

37	Has any yard hydrant been provided from the building's fire pump?	NA
38	Where more than one lifts are installed in a common enclosure have individual lifts been separated by fire resisting walls or 2 hours fire rating?	NA
39	Has the lift shaft(s) lift lobby or stairwell been pressurized? If so, give details.	Na
40	Have the lift lobbies and staircase been effectively enclosed to prevent fire/smoke entering them from outside at any floor?	NO
41	Have all exists and direction of travel to each exit been sign-posted with illuminated signs?	NO
42	Has a false ceiling been provided in any portion of the building? If so, please indicate location and also mention if the material used for the false ceiling is combustible or non-combustible.	Yes Gypsum board
43	<p>Is the building centrally air-conditioned? If so, please indicate</p> <p>a. The material used for construction of duct and its fittings.</p> <p>b. The type of tinning used for ducts, if any</p> <p>c. The type of lagging used, if any for insulating any portion of the duct, please also indicate how the lagging is secured.</p> <p>d. If false ceiling is provided, please give information as at 42 above</p> <p>e. If plenum is used a return air passage has it been protected with fire detectors? Please give details.</p> <p>f. Has a separate AHU been provided for each floor?</p> <p>g. Whether automatic shut down of AHU is coupled with detection system?</p>	NO



PRESIDENT
KNOWLEDGE PUBLIC SCHOOL
TIMARNI


Secretary
Rasundew Shikshan & Samaj
Samiti, Timarni
Rasundew Samiti, Timarni


PRINCIPAL
KNOWLEDGE PUBLIC SCHOOL
TIMARNI

	<p>h. Is the ducting for each floor effectively isolated or is it continuous or more than one floors?</p> <p>i. Are the fire dampers being provided?</p>	
44	<p>Where are the switchgear and transformers located? If inside the building, please indicate.</p> <p>a. If the switchgear and transformer(s) have been housed in separate compartments, effectively separated from each other and from other portion of the buildings by a four hours fire resistive wall?</p> <p>b. What precautions have been taken to prevent a possible fire in the transformer(s) from spreading?</p>	<p>Switch gear & transformers is located outside the building</p> <p>NA</p>
45	<p>I Where electric cables, telephone cables, dry/wet risers/down comers pass through a floor or wall have the spaces (apertures) round the cables/pipes been effectively sealed/plugged with non-combustible, fire resistant material?</p> <p>II Ventilation</p> <p>a. Whether natural ventilation is relied upon? If so give details of the vents for the stairwell, lift shaft.</p> <p>b. Whether mechanic ventilation has been proposed? If so, give details of the proposed system indicating the number of air changes for the basement and other floors.</p> <p>c. Whether mechanical ventilation is coupled with</p>	<p>Yes</p> <p>yes as per NBC & MPBVR 1984</p> <p>NA</p> <p>NA</p>
46	<p>Please indicate the number and type of fire extinguishers provided at various indications and the arrangement for the maintenance of the extinguishers.</p>	<p>ABC -06 nos</p> <p>Co2 -03 nos</p> <p>AS per IS</p>



PRESIDENT
KNOWLEDGE PUBLIC SCHOOL
TIMARNI


Secretary
Kusumdevi Shikshan & Samaj
Samiti, Timarni


PRINCIPAL
KNOWLEDGE PUBLIC SCHOOL
TIMARNI

47	Please indicate if all fire extinguishers bear the ISI certification mark.	YES ISI marked
48	Whether the refuge area has been provided? If so, the floor on which provided and the total area provided floor-wise.	NA
49	Are the occupants of the building systematically trained in fire prevention, use of fire extinguishers and emergency procedures? If so, please give details.	Shall be Train
50	Does an emergency organization exist in the building? If so, please give details and append a copy of the emergency (Fire) orders	NA
51	Has a qualified Fire Officer been appointed for the building either individually or jointly with other building(s)	NA
52	Has the building been protected against lightening? If so, does the lightening protect confirm to any code? Please indicate details.	NO
53	The work has not been started on site and construction will be started only after final approval of the Competent Authority the position of construction site is given below:	Building Constructed

OWNER'S SIG.


PRESIDENT
KNOWLEDGE PUBLIC SCHOOL
TIMARNI

Fire consultants signatures


Secretary
Kesumdevi Shikshan & Samaj
Kalyan Samiti, Timarni


PRINCIPAL
KNOWLEDGE PUBLIC SCHOOL
TIMARNI